



## Evaluation Listing CCMC 13312-L

MASTERFORMAT: 07 54 19.03  
Issued: 2008-04-24  
Revised: 2009-07-29  
Re-evaluation due: 2011-04-24

---

### **Sure-Flex PVC / Mule Hide PVC**

#### **1. Evaluation**

Conforms to CAN/CGSB-37.54-95, "Polyvinyl Chloride Roofing and Waterproofing Membrane," Type 4, Class B.

#### **2. Description**

Carlisle SynTec Inc.'s "Sure-Flex PVC/Mule Hide PVC" are composed of three layers: a polyvinyl chloride (PVC) polymer bottom ply, a polyester-reinforced fabric (scrim), and a thermoplastic PVC compounded top ply.

#### **3. Standard and Regulatory Information**

The roofing and waterproofing membranes are suitable for use in exposed and non-exposed applications. Only materials recommended by the manufacturer should be in contact with the membranes. Follow the manufacturer's installation recommendations.

See the [Preface](#) and the standard for explanation.

Listing Holder: Carlisle SynTec Canada  
2910 South Sheridan Drive, Unit #107  
Oakville, ON L6J 7J8  
Tel: 800-387-4990  
Fax: 905-829-2899

Plant(s): Oakville, ON

*This Listing is issued by the Canadian Construction Materials Centre, a program of the Institute for Research in Construction at the National Research Council of Canada. The Listing must be read in the context of the entire CCMC Registry of Product Evaluations.*

*Readers must confirm that the Listing is current and has not been withdrawn or superseded by a later issue. Please refer to <http://www.nrc-cnrc.gc.ca/eng/services/irc/ccmc.html>, or contact the Canadian Construction Materials Centre, Institute for Research in Construction, National Research Council of Canada, 1200 Montreal Road, Ottawa, Ontario, K1A 0R6. Telephone (613) 993-6189. Fax (613) 952-0268.*

***NRC has evaluated the material, product, system or service described herein only for those characteristics stated herein. The information and opinions in this Listing are directed to those who have the appropriate degree of experience to use and apply its contents. This Listing is provided without representation, warranty, or guarantee of any kind, expressed, or implied, and the National Research Council of Canada (NRC) provides no endorsement for any evaluated material, product, system or service described herein. NRC accepts no responsibility whatsoever arising in any way from any and all use and reliance on the information contained in this Listing. NRC is not undertaking to render professional or other services on behalf of any person or entity nor to perform any duty owed by any person or entity to another person or entity.***