



**BUILDING CODE COMPLIANCE OFFICE (BCCO)
PRODUCT CONTROL DIVISION**

**MIAMI-DADE COUNTY, FLORIDA
METRO-DADE FLAGLER BUILDING
140 WEST FLAGLER STREET, SUITE 1603
MIAMI, FLORIDA 33130-1563
(305) 375-2901 FAX (305) 375-2908**

NOTICE OF ACCEPTANCE (NOA)

**Mule-Hide Products Co., Inc.
1195 Prince Hall Dr.
Beloit, WI 53511**

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed by Miami-Dade County Product Control Division and accepted by the Board of Rules and Appeals (BORA) to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Division (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. BORA reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Division that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code, including the High Velocity Hurricane Zone.

DESCRIPTION: Mule-Hide Single Ply EPDM Roof Systems over Lightweight Concrete Decks

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This new NOA consists of pages 1 through 7.
The submitted documentation was reviewed by Frank Zuloaga, RRC



**NOA No.: 03-0703.05
Expiration Date: 01/27/10
Approval Date: 01/27/05
Page 1 of 7**

ROOFING SYSTEM APPROVAL

Category: Roofing
Sub-Category: 07530 Single Ply
Material: EPDM
Deck Type: Lightweight Concrete
Maximum Design Pressure -262.5 psf
Fire Classification: See General Limitation #1

TRADE NAMES OF PRODUCTS MANUFACTURED OR LABELED BY APPLICANT:

TABLE 1

<u>Product Name</u>	<u>Dimensions</u>	<u>Test Specifications</u>	<u>Product Description</u>
Standard Black EPDM	various	ASTM D 4637	Non-reinforced EPDM membrane.
FR EPDM	various	ASTM D 4637	Non-reinforced, fire retardant EPDM membrane.
FR-Plus EPDM			
Reinforced EPDM	various	ASTM D 4637	Reinforced EPDM membrane.
Sure-Tough			
Reinforced FR EPDM	various	ASTM D 4637	Reinforced, fire retardant EPDM membrane.
Fleece BACK	various	ASTM D 4637	EPDM membrane with fleece backing..
Fleece BACK AFX			
White-on-Black EPDM	various	ASTM D 4637	Non-reinforced white on black EPDM membrane.
White-On-Black Fleece BACK EPDM	Various	ASTM D4637	Non-reinforced white on black fleece backed EPDM membrane.
RMS	various	ASTM D 4637	Reinforced securement strip.
Tape Primer	various	TAS 110	Solvent-Based Primer
CCW 702LT Primer	various	TAS 110	Low-Temperature Solvent-Based Primer
CCW 714 Primer	various	TAS 110	Water-Based Primer
CCW 725 Vapor Barrier	various	TAS 110	Vapor Barrier
FAST 100 Adhesive	various	TAS 110	Spray Polyurethane Adhesive
FAST 100-LV Adhesive			
FAST 100-P Adhesive			
FAST 102 Adhesive			
All-Purpose Sealant (white)		TAS 110	Lap Sealant for White-on-Black, Black EPDM membranes.
Black Lap Sealant			
White Splice Cement		TAS 110	Splicing Adhesive for EPDM membranes.
Black Splice Cement			
In-Seam Tape		TAS 110	Tape Adhesive for EPDM membranes.
Mule-Hide Bonding Adhesive		TAS 110	Solvent based bonding adhesive.



NOA No.: 03-0703.05
 Expiration Date: 01/27/10
 Approval Date: 01/27/05
 Page 2 of 7

B-500 Bonding Adhesive	TAS 110	Water-based bonding adhesive.
Mule-Hide Water Base Bonding Adhesive	TAS 110	Water-based bonding adhesive.

APPROVED INSULATIONS:

TABLE 2

Product Name	Product Description	Manufacturer (With Current NOA)
N/A	N/A	N/A

APPROVED FASTENERS:

TABLE 3

Fastener Number	Product Name	Product Description	Dimensions	Manufacturer (With Current NOA)
1.	N/A	N/A	N/A	N/A

EVIDENCE SUBMITTED

<u>Test Agency</u>	<u>Test Identifier</u>	<u>Description</u>	<u>Date</u>
Architectural Testing Inc.	ATI-17601-01	Wind Uplift Classification	06/29/96
Architectural Testing Inc.	ATI-17601-02	Wind Uplift Classification	07/30/96
Architectural Testing Inc.	ATI-18535	Wind Uplift Classification	10/14/96
Factory Mutual Research Corp.	J.I. 2Z3A9.AM	Wind Uplift and Fire Classification	07/30/97
Factory Mutual Research Corp.	J.I. 4B2A1.AM	Wind Uplift Classification	06/11/97
Factory Mutual Research Corp.	J.I.3B8Q4.AM	Wind Uplift Classification	06/04/97
Factory Mutual Research Corp.	J.I. 3B5A1.AM	Wind Uplift and Fire Classification	04/28/97
Factory Mutual Research Corp.	J.I. 2Z2A8.AM	Seam Test	05/16/97
Factory Mutual Research Corp.	J.I. 0B4A7.AM	Wind Uplift Classification	05/29/97
Factory Mutual Research Corp.	J.I. 2B2A1.AM	Wind Uplift Classification	05/29/97
Factory Mutual Research Corp.	J.I.1B7A5.AM	Wind Uplift and Fire Classification	02/23/98
Factory Mutual Research Corp.	J.I. 2D6A6.AM	Wind Uplift Classification	10/7/98
Factory Mutual Research Corp.	3016162	Class 4470	11/25/03
Factory Mutual Research Corp.	J.I. 1B7A4.AM	Class 4470	07/08/99
Underwriters Laboratories, Inc.	96NK21757	Fire Classification	09/06/96
Underwriters Laboratories, Inc.	96NK10924	Fire Classification	10/31/96
Underwriters Laboratories, Inc.	96NK28871	Fire Classification	11/06/96
Underwriters Laboratories, Inc.	96NK33323	Fire Classification	10/24/97
Underwriters Laboratories, Inc.	02NK46936	UL 790	12/15/03



APPROVED ASSEMBLIES

Membrane Type: Single Ply, Thermoset, EPDM, Reinforced and Noneinforced and FleeceBacked

Deck Type 4: Lightweight Concrete, Uninsulated, over Steel Deck

Deck Description: Cellular or Aggregate Lightweight Concrete

System Type F-1: Membrane fully adhered to primed lightweight insulating concrete deck.

All General and System Limitations apply.

Vapor Retarder: None

Membrane: Standard or White-on-Black 45 to 90 mil membranes fully adhered to the lightweight deck using Mule-Hide Bonding Adhesive applied to the substrate at a rate of 1 gal/60 ft.² or B-500 applied to the substrate at 1 gal./sq.

Or

FleeceBACK or White-on-Black FleeceBACK 100 or 115 mil membrane fully adhered to the lightweight deck using FAST Adhesive applied to the substrate at a rate of 1 gal/sq.

Surfacing: (Optional) A two-part surfacing consisting of EM-8 Hypalon applied at the rate of 1 gal./150 ft² and silica sand applied into the wet coating at a rate of 35 lbs./sq. or two coats of Mule-Hide Acrylic Coating at a rate 1.5 gal/sq. per coat.

Maximum Design Pressure: -45 psf. (See General Limitation #9)



Membrane Type: Single Ply, Thermoset, EPDM, Reinforced and Noneinforced and FleeceBacked
Deck Type 4: Lightweight Concrete, Uninsulated, over Steel Deck
Deck Description: Celcore Cellular Lightweight Concrete over 18-22 ga Steel Deck
System Type F-2: Membrane fully adhered to primed lightweight insulating concrete deck.

All General and System Limitations apply.

Deck: Minimum 22 ga. steel deck secured to supports space at maximum 4 ft o.c. with ITW Buildex Traxx/5 spaced at 6" o.c.

Vapor Retarder: None

Membrane: FleeceBACK or White-on-Black FleeceBACK 100 or 115 mil membrane fully adhered to the lightweight deck using FAST Adhesive applied to the substrate at a rate of 1 gal/sq.

Surfacing: (Optional) A two-part surfacing consisting of EM-8 Hypalon applied at the rate of 1 gal./150 ft² and silica sand applied into the wet coating at a rate of 35 lbs./sq. or two coats of Mule-Hide Acrylic Coating at a rate 1.5 gal/sq. per coat.

Maximum Design Pressure: -90 psf. (See General Limitation #9)

Membrane Type: Single Ply, Thermoset, EPDM, Reinforced and Noneinforced and FleeceBacked
Deck Type 4: Celcore Lightweight Insulating Concrete, over Structural Concrete Deck
Deck Description: Celcore Lightweight Insulating Concrete
System Type F-3: Membrane fully adhered to primed lightweight insulating concrete deck.

All General and System Limitations apply.

Vapor Retarder: None

Membrane: FleeceBACK or White-on-Black FleeceBACK 100 or 115 mil membrane fully adhered to the lightweight deck using FAST adhesive applied to the substrate at a rate of 1 gal./sq.

Surfacing: (Optional) A two-part surfacing consisting of EM-8 Hypalon applied at the rate of 1 gal./150 ft² and silica sand applied into the wet coating at a rate of 35 lbs./sq. or two coats of Mule-Hide Acrylic Coating at a rate 1.5 gal/sq. per coat.

Maximum Design Pressure: -262.5 psf. (See General Limitaiton #9)



Membrane Type: Single Ply, Thermoset, EPDM, Reinforced and Noneinforced and FleeceBacked

Deck Type 4: Elastizell Range II Lightweight Insulating Concrete, over Structural Concrete Deck

Deck Description: Elastizell Range II Lightweight Insulating Concrete

System Type F-4: Membrane fully adhered to primed lightweight insulating concrete deck.

All General and System Limitations apply.

Vapor Retarder: None

Membrane: FleeceBACK or White-on-Black FleeceBACK 100 or 115 mil membrane fully adhered to the lightweight deck using FAST adhesive applied to the substrate at a rate of 1 gal./sq.

Surfacing: (Optional) A two-part surfacing consisting of EM-8 Hypalon applied at the rate of 1 gal./150 ft² and silica sand applied into the wet coating at a rate of 35 lbs./sq. or two coats of Mule-Hide Acrylic Coating at a rate 1.5 gal/sq. per coat.

Maximum Design Pressure: -205 psf. (See General Limitaiton #9)

LIGHTWEIGHT INSULATING CONCRETE SYSTEM LIMITATIONS:

1. For steel deck application where specific deck construction is not referenced: The deck shall be a minimum 22 gage attached with ⁵/₈" puddle welds with weld washers at every flute with maximum deck spans of 5 ft. o.c.
2. For Systems where specific lightweight insulating concrete is referenced consult current lightweight insulating concrete NOA for specific deck construction and limitations. For systems where specific lightweight insulating concrete is not referenced, the minimum design mix shall be a minimum of 300 psi.



GENERAL LIMITATIONS:

1. Fire classification is not part of this acceptance, refer to a current Approved Roofing Materials Directory for fire ratings of this product.
2. Insulation may be installed in multiple layers. The first layer shall be attached in compliance with Product Control Approval guidelines. All other layers shall be adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq., or mechanically attached using the fastening pattern of the top layer
3. All standard panel sizes are acceptable for mechanical attachment. When applied in approved asphalt, panel size shall be 4' x 4' maximum.
4. An overlay and/or recovery board insulation panel is required on all applications over closed cell foam insulations when the base sheet is fully mopped. If no recovery board is used the base sheet shall be applied using spot mopping with approved asphalt, 12" diameter circles, 24" o.c.; or strip mopped 8" ribbons in three rows, one at each sidelap and one down the center of the sheet allowing a continuous area of ventilation. Encircling of the strips is not acceptable. A 6" break shall be placed every 12' in each ribbon to allow cross ventilation. Asphalt application of either system shall be at a minimum rate of 12 lbs./sq. **Note: Spot attached systems shall be limited to a maximum design pressure of -45 psf.**
5. Fastener spacing for insulation attachment is based on a Minimum Characteristic Force (F') value of 275 lbf., as tested in compliance with Testing Application Standard TAS 105. If the fastener value, as field-tested, are below 275 lbf. insulation attachment shall not be acceptable.
6. Fastener spacing for mechanical attachment of anchor/base sheet or membrane attachment is based on a minimum fastener resistance value in conjunction with the maximum design value listed within a specific system. Should the fastener resistance be less than that required, as determined by the Building Official, a revised fastener spacing, prepared, signed and sealed by a Florida Registered Engineer, Architect, or Registered Roof Consultant may be submitted. Said revised fastener spacing shall utilize the withdrawal resistance value taken from Testing Application Standards TAS 105 and calculations in compliance with Roofing Application Standard RAS 117.
7. Perimeter and corner areas shall comply with the enhanced uplift pressure requirements of these areas. Fastener densities shall be increased for both insulation and base sheet as calculated in compliance with Roofing Application Standard RAS 117. **(When this limitation is specifically referred within this NOA, General Limitation #9 will not be applicable.)**
8. All attachment and sizing of perimeter nailers, metal profile, and/or flashing termination designs shall conform with Roofing Application Standard RAS 111 and applicable wind load requirements.
9. The maximum designed pressure limitation listed shall be applicable to all roof pressure zones (i.e. field, perimeters, and corners). Neither rational analysis, nor extrapolation shall be permitted for enhanced fastening at enhanced pressure zones (i.e. perimeters, extended corners and corners). **(When this limitation is specifically referred within this NOA, General Limitation #7 will not be applicable.)**
10. All products listed herein shall have a quality assurance audit in accordance with the Florida Building Code and Rule 9B-72 of the Florida Administrative Code.

END OF THIS ACCEPTANCE



NOA No.: 03-0703.05
Expiration Date: 01/27/10
Approval Date: 01/27/05
Page 7 of 7