

# PARAPET WALL FLASHING HEIGHT EXCEEDING 30"

MAXIMUM WALL HEIGHT WITHOUT INTERMITTENT FASTENING IS 33" (WHEN CANTS ARE NOT INSTALLED). FOR WALLS HIGHER THAN 30", INTERMITTENT FASTENING IS EVERY 33" TO 36" MAXIMUM DEPENDING ON TYPE OF FASTENERS USED. IF ATTACHING WITH CAP NAILS THE SEAM WIDTH SHALL BE 3". IF USING INSULATION PLATES AND FASTENERS, THE SEAM WIDTH SHALL BE 6". FASTENERS SHALL BE SPACED A MAXIMUM OF 6" ON CENTER.

NOTE: 20-YR WARRANTIES REQUIRE 2 PLYS OF SA BASE SHEET INSTALLED ON THE FIELD OF THE ROOF AND 1 PLY ON ALL VERTICAL SURFACES.

SA-SBS CAP SHEET  
OR SA-APP CAP SHEET

2 PLYS SA BASE SHEET

SA-SBS CAP SHEET  
OR SA-APP CAP SHEET  
ADHERED TO PRIMED  
SURFACE.

METAL COPING (BY OTHERS)

M-H MOD BIT SEALANT

33"

6"

CAP SHEET MUST TURN UP THE VERTICAL SURFACE A MINIMUM OF 4". SA BASE SHEET MUST TURN UP THE VERTICAL SURFACE A MINIMUM OF 3". WHEN FLASHING WITH THE SA BASE SHEET, THE SHEET MUST TURN OUT ONTO THE FIELD A MINIMUM OF 3".

MULE-HIDE DOES NOT REQUIRE BUT RECOMMENDS CANTS (CANTS ARE OPTIONAL). THE VERTICAL SURFACE OF THE CAP SHEET MUST BE SOFTENED OR MUST BE COATED WITH MOD BIT FLASHING ADHESIVE PRIOR TO INSTALLING FLASHING MATERIAL.

APPROVED INSULATION MECHANICALLY ATTACHED FOLLOWING FM GUIDELINES

**NOTES:**

1. VERTICAL SURFACES SUCH AS MASONRY, CONCRETE, AGED WOOD OR METAL SHALL BE PRIMED WITH MULE-HIDE # 121 ASPHALT PRIMER.
2. FLASHING MATERIAL MAY BE SET IN A BED OF MULE-HIDE MOD BIT FLASHING ADHESIVE OR MAY BE HOT AIR WELDED TO FIELD SHEET. IF HOT AIR WELDING, ENTIRE 6" WIDE SEAM MUST BE SEALED.

**MULE-HIDE  
PRODUCTS CO.,INC.  
2003**

**BASE FLASHING - OPTION 8  
SELF-ADHERING MOD BIT SYSTEMS**

**DETAIL NO.:  
MH-MB-BF8**